



## Certification

**Company** IGP Pulvertechnik AG  
Industrie Stelz, Kirchberg  
9500 Wil  
Switzerland

proved within the scope of an inspection for the Mark of Conformity (Ü-Mark) on 17 June 2010 in accordance with the Building Rules List A Part 1, Edition 2010/1 for

## Product

***"Coating materials: Corrosion protection of steel constructions by means of coating systems"***

### **Steel / Hot-dip galvanized / Yellow chromitized**

Primer	Top coat	Area of coating thickness	Corrosivity category
Korroprimer NT18	Duraface 5807	80 + 80 µm	C5 I/M long

Test report no. I0A089 of 17.06.2010 serves as basis for this certification. By that, the manufacturer is entitled to mark the construction products in accordance with the Mark of Conformity-Regulation with the Mark of Conformity (Ü-Mark). Apart from that, he is obliged to notify the inspection authority of essential changes or supplements in or to the defined field of application.

## Inspection Authority

for the inspection of construction products used in metal constructions according to § 25 para. 1 sentences 1 no. 1 and 2 of LBO (state building regulations) Baden-Württemberg

Schwäbisch Gmünd, 13.10.2010

Deputy Inspection Authority Manager  
Dipl.-Chem. Marc Holz